

# CERTIFICATE OF COMPLIANCE

**Certificate Number** EX15200  
**Report Reference** EX15200-2007-03-09  
**Date** 2021-May-19

**Issued to:** AL JAZEERA STEEL PRODUCTS CO SAOG  
Po Box 40  
Sohar Industrial Estate  
Sultanate Of Oman327 OM

**This is to certify that representative samples of** METALLIC SPRINKLER PIPE  
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** UL 852, Metallic Sprinkler Pipe for Fire Protection Service

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** EX15200  
**Report Reference** EX15200-2007-03-09  
**Date** 2021-May-19

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

**Models:**


Schedule 40 (black or galvanized) steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6 and 8 in. sizes as per ASTM A53, Grade A, Type E.

Schedule 40 (black or galvanized) steel pipe in the 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6 and 8 in. sizes as per ASTM A53, Grade B, Type E.

Schedule 10 (black or galvanized) steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, and 8 in. sizes as per ASTM A53 and ASTM A795, Grade A, Type E.

Schedule 10 (black or galvanized) steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, and 8 in. sizes as per ASTM A53 and ASTM A795, Grade B, Type E.

All pipes with threaded ends shall conform to ANSI B1.20.1.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

